

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 7300-1615:0168 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450  
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263  
Email: jon.wolski@us.bosch.com

**DESIGN:** Model D6600 Digital Alarm Communicator Receiver (DACR). Unit is intended for receiving alarm signals in a central monitoring station. The unit is provided in an enclosure suitable for installation in a standard 19" rack. The unit supports a maximum of 32 incoming telephone lines. It also is provided with two serial ports and one parallel port. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

D6600; Receiver  
D6610; CPU Card  
D6615; CPU Terminator Card  
D6630; AC/DC Power Supply Module  
D6631; DC/DC Power Supply Module  
D6640; Telephone Line Card  
\*D6641; Line Card  
D6645; Telephone Terminator Card  
SC9002; External Printer

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as a digital alarm communicator receiver control unit for central station monitoring services. Refer to listee's Installation Instruction Manual for details.

\*Rev. 01-14-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**  
*Fire Engineering Division*