

消防處  
牌照及審批總區  
香港九龍尖沙咀東部康莊道1號5樓  
消防總部大廈



**FIRE SERVICES DEPARTMENT  
LICENSING AND CERTIFICATION  
COMMAND**

FIRE SERVICES HEADQUARTERS BUILDING,  
No. 1 Hong Chong Road, 5/F.,  
Tsim Sha Tsui East, Kowloon,  
Hong Kong

本處檔號 Our Ref.: (18) in FP 206/0994

來函檔號 Your Ref.: L0204101

電訊掛號 Telex: 39607 HKFSD HX

圖文傳真 Fax: (852) 2367 3631

電子郵件 E-mail: lcpolic2@hkfsd.gov.hk

電話 Tel. No.: 2733 7744

11 June 2002

Detection Systems (HK) Limited  
12/F, Metropole Square  
2 On Yiu Street  
Shatin, N.T.

Dear Sirs,

**DS Fire Protection Products**

I refer to my interim reply of 12.4.2002 on the captioned subject.

The proposed use of the following equipment, which was certified by Underwriters Laboratories Inc. (UL), is acceptable to this Department.

<b>Manufacturer</b>	:	Radionics, Division of Detection Systems Inc.
<b>Type</b>	:	Digital Alarm Communicator Receiver
<b>Model</b>	:	D6600
<b>Testing Standards</b>	:	i) UL 864, Control Units for Fire Signaling Systems ii) UL 1635, Digital Alarm Communicator Units
<b>Supporting Document</b>	:	Test Report File S1871 Project 97SC14342 issued by UL on 10 February 1999 and last revised on 1 February 2002.

Please note that the acceptance of the above is subject to :-

- i) the installation conforming to the LPC Rules for Automatic Fire Detection and Alarm Installations for the Protection of Property ;
- ii) all conditions as stipulated in the above-mentioned report being complied with; and

...../P.2

iii) all components used in the installation being compatible.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'Lau Kwai-shan', with a stylized, flowing script.

(LAU Kwai-shan)  
for Director of Fire Services

LKS/RL/cwy