MB-FPI Fire Phone Interface

www.boschsecurity.com



Provides 4 supervised Class B Fire Phone circuits in distributed panel (4 max 16 circuits). When more than one is used in a HMB-DP Master Panel a MB-FPO2 Fire Phone Output Adapter is required for each.

Certifications and approvals

Region	Certification	
USA	UL	UOXX: Control Unit Accessories, System (ANSI/UL 864)
	CSFM	see our website

Ordering information

MB-FPI Fire Phone Interface

Provides 4 supervised Class B Fire Phone circuits in distributed panel (4 max 16 circuits). When more than one is used in a HMB-DP Master Panel a MB-FPO2 Fire Phone Output Adapter is required for each. Order number MB-FPI